

Items 2.8, 2.8.1, 2.8.2, 2.8.3, 2.8.4 replace defective tile listing with new and re-render margin of walling



Items 2.9, 2.9.1, 2.9.2, 2.9.3 replace defective tile listing with new

Items 2.10 rake out and repoint all defective coping joints

leave this tile listing here

Items 2.11 provisionally allow to replace 1No. defective coping stone




Item 2.7 repoint defective joints to ridge tiles

Item 2.3.1 tiling maintenance

Notes:

1. This drawing is to be read in conjunction with all Architect's drawings and Specification and all relevant contract documentation.
2. Drawings must not be scaled. The contractor is to verify all dimensions and details on site, and is to report any discrepancies to the architect immediately.
3. The contractor is to carry out everything necessary for the proper execution of the works whether or not shown on the drawings or described in the Specification provided the same may reasonably be inferred therefrom.
4. All work is to comply with relevant British Standards and Codes of Practice in respect of materials and workmanship, and site procedure and organisation, and specifically with BS 2000-0:2014.
5. If in doubt - ask!



Item 3.5.1 rake out defective cement flashing behind flashing to parapet and redo in hot lime mortar

NAVE, SOUTH SLOPE - WEST ABUTMENT

SOUTH AISLE - WEST PARAPET


NAVE, SOUTH SLOPE - EAST ABUTMENT

Items 3.2, 3.2.1, 3.2.2 remove moss to parapet; rake out and repoint 3Nos. defective coping joints; rake out and repoint defective pointing to flashing



SOUTH AISLE - EAST PARAPET

Items 3.1, 3.1.1 carry out maintenance to aisle roof



SOUTH AISLE - WEST PARAPET

Items 3.5, 3.5.1, 3.5.2, 3.5.3, 3.5.4 take off, consolidate and rebed the 3Nos. bottom loose copings; repoint all defective copings; rake out and replace cement flashing behind flashing, as shown above; redress and repoint extg flashing back into place

Item 12.6 rake out and repoint area of defective pointing
Item 12.6.1 rebuild kneeler stone in rightful position



NORTH AISLE - WEST PARAPET

drawing title		ASHLEY COURTNEY RIBA AABC ARCHITECT				
PHOTOS IDENTIFYING PROPOSED WORKS		36 Roseford Road, Cambridge CB4 2HD tel: 01223 750610 email: ac@ashleycourtney.co.uk				
client	job title	scale	date	job no.	dwg no.	rev
COTON PCC	URGENT REPAIRS	NTS	NOV 2020	20-27	05	